

## Assessment Summary for Two-Panel Hinged, Semi-Automatic, Lift Landing Doorsets

### Scope of Assessment

This summary has been prepared by Exova Warringtonfire and is a summary of the assessment report referenced below. Full details of the construction, justification for the conclusions given, along with validity statements are given in that report.

The lift landing doorsets have been appraised for **120 minutes integrity** performance and **60 minutes radiation** performance with respect to EN 81-58: 2003.

Report Reference	Period of Validity
WF Report No. 306474 (Issue 2)	Until 1 <sup>st</sup> May 2016

### Appraised Scope

Clear Opening Size Range (mm)			
Min. Width	Max. Width	Min. Height	Max. Height
910	1700	1700	2400
910	1700	1700	2400

*This Assessment Summary is based upon a report prepared by Exova Warringtonfire. Full details of the constructions and justification for any opinions given, along with validity statements, are given in the referenced assessment report. The assessment report does not provide an endorsement by Exova Warringtonfire of the performance of the actual products supplied.*

*This Assessment Summary has been compiled between Exova Warringtonfire and Klefer SA. It is intended to provide a brief outline of the above referenced assessment report and does not replace it.*

Full copies of the assessment may be obtained from:

**Klefer SA**, Kilkis Industrial Area, Stavroxiri, Greece  
 Tel : + 30 23410 75730-2  
 Fax : + 30 23410 75733