

Assessment Summary for PRT and PRC Lift Landing Doorsets

Scope of Assessment

This summary has been prepared by Exova Warringtonfire and is a summary of the assessment report referenced below. Full details of the construction, justification for the conclusions given, along with validity statements are given in that report.

The lift landing doorsets have been appraised for **120 minutes integrity** performance (**E120**) with respect to EN 81-58: 2003.

Report Reference	Period of Validity
WF Assessment Report No. 310093	Until 1 st August 2016

Appraised Scope

Door Type	Clear Opening Size Range (mm)			
	Min. Width	Max. Width	Min. Height	Max. Height
PRT1H	600	800	2000	2600
PRT2H	600	1600	2000	2600
PRT3H	600	2000	2000	2600
PRT4H	600	2500	2000	2600
PRC2H	600	1600	2000	2600
PRC4H	600	3000	2000	2600
PRC6H	1200	3100	2000	2600
PRC8H	1400	3100	2000	2600
Additional Optional Modifications	<p>The doorset may incorporate various side-panel, control box and frame post configurations, as shown on the drawings appended to the original report.</p> <p>The door frame may be installed in any of the following three ways:</p> <ul style="list-style-type: none"> • Inside the reveal of the opening with an adjustable steel profile surrounding the perimeter • Inside the reveal of the opening with the perimeter of the doorset infilled with concrete. • Face fixed to the 'shaft' face of the wall. 			

This Assessment Summary is based upon a report prepared by Exova Warringtonfire. Full details of the constructions and justification for any opinions given, along with validity statements, are given in the referenced assessment report. The assessment report does not provide an endorsement by Exova Warringtonfire of the performance of the actual products supplied.

This Assessment Summary has been compiled between Exova Warringtonfire and Klefer SA. It is intended to provide a brief outline of the above referenced assessment report and does not replace it.

Full copies of the assessment may be obtained from:

Klefer SA, Kilkis Industrial Area, Stavroxiri, Greece