

Assessment Summary for Klefer Lift Landing Doorsets

Scope of Assessment

This summary has been prepared by Exova Warringtonfire and is a summary of the assessment report referenced below. Full details of the construction, justification for the conclusions given, along with validity statements are given in that report.

The lift landing doorsets have been appraised for **60 minutes integrity and insulation** performance (**E160**) with respect to EN 81-58: 2003.

Report Reference

WF Assessment Report No. 167510A

Period of Validity

Until 1st November 2017

Appraised Scope

Door Type	Clear Opening Size Range (mm)			
	Min. Width	Max. Width	Min. Height	Max. Height
T1	600	800	2000	2600
T2	600	1600	2000	2600
T3	600	2000	2000	2600
T4	600	2500	2000	2600
C2	600	1600	2000	2600
C4	600	3000	2000	2600
C6	1200	3100	2000	2600
C8	1200	3100	2000	2600
Additional Optional Modifications	<p>The doorset may incorporate various side-panel, control box and frame post configurations, as shown on the drawings appended to the original report.</p> <p>The door panels shall be insulated with Liftbifire of 18 mm thickness.</p> <p>The door frame may be installed in any of the following three ways:</p> <ul style="list-style-type: none"> • Inside the reveal of the opening with an adjustable steel profile surrounding the perimeter • Inside the reveal of the opening with the perimeter of the doorset infilled with concrete. • Face fixed to the 'shaft' face of the wall. 			

This Assessment Summary is based upon a report prepared by Exova Warringtonfire. Full details of the constructions and justification for any opinions given, along with validity statements, are given in the referenced assessment report. The assessment report does not provide an endorsement by Exova Warringtonfire of the performance of the actual products supplied.

This Assessment Summary has been compiled by Exova Warringtonfire. It is intended to provide a brief outline of the above referenced assessment report and does not replace it.