

Assessment Summary for Klefer Glazed Lift Landing Doorsets

Scope of Assessment

This summary has been prepared by Exova Warringtonfire and is a summary of the assessment report referenced below. Full details of the construction, justification for the conclusions given, along with validity statements are given in that report.

The lift landing doorsets have been appraised for **30 minutes integrity and insulation** performance (**EI30**) with respect to EN 81-58: 2003.

Report Reference	Period of Validity
WF Report No. 167510D	Until 1 st November 2017

Appraised Scope

Door Type	Clear Opening Size Range (mm)			
	Min. Width	Max. Width	Min. Height	Max. Height
PRT2H	600	1200	2000	2400
PRC2H	600	1200	2000	2400
PRC4H	1000	2300	2000	2400
Additional Optional Modifications	<p>The doorset may incorporate various side-panel, control box and frame post configurations, as shown on the drawings appended to the original report.</p> <p>The door frame may be installed in any of the following three ways:</p> <ul style="list-style-type: none"> Inside the reveal of the opening with an adjustable steel profile surrounding the perimeter Inside the reveal of the opening with the perimeter of the doorset infilled with concrete. Face fixed to the 'shaft' face of the wall. <p>Various optional modifications to the specifications of the insulation materials and the glass.</p>			

This Assessment Summary is based upon a report prepared by Exova Warringtonfire. Full details of the constructions and justification for any opinions given, along with validity statements, are given in the referenced assessment report. The assessment report does not provide an endorsement by Exova Warringtonfire of the performance of the actual products supplied.

This Assessment Summary has been compiled by Exova Warringtonfire. It is intended to provide a brief outline of the above referenced assessment report and does not replace it.