



Assessment Summary for GLOBAL, FERMATOR and SKOTIA Hinged, Semi-Automatic, Lift Landing Doorsets

Scope of Assessment

This summary has been prepared by Bodycote **warringtonfire** and is a summary of the assessment report referenced below. Full details of the construction, justification for the conclusions given, along with validity statements are given in that report.

The lift landing doorsets have been appraised for **120 minutes integrity** performance (**E120**) with respect to EN 81-58: 2003.

Report Reference	Period of Validity
WF Report No. 184409	Until 1 st August 2014

Appraised Scope

Door Type	Clear Opening Size Range (mm)			
	Min. Width	Max. Width	Min. Height	Max. Height
GLOBAL	600	1000	1700	2300
FERMATOR	600	1000	1700	2300
SKOTIA	600	1000	1700	2300
Additional Optional Modifications	The doorsets may incorporate a glazed vision panel. The doorset may be face fixed to the shaft of the wall or alternatively installed inside the reveal of the wall opening.			

*This Assessment Summary is based upon a report prepared by Exova **warringtonfire**. Full details of the constructions and justification for any opinions given, along with validity statements, are given in the referenced assessment report. The assessment report does not provide an endorsement by Exova **warringtonfire** of the performance of the actual products supplied.*

*This Assessment Summary has been compiled between Exova **warringtonfire** and **Klefer SA**. It is intended to provide a brief outline of the above referenced assessment report and does not replace it.*

Full copies of the assessment may be obtained from:

Klefer SA, Kilkis Industrial Area, Stavroxiri, Greece